

MPT90 M1



A - Power supply

110 = 115 Vac
220 = 230 Vac
24 = 25 Vac
VCC = 12÷30 Vdc

B - Output

A = Main relay output
C = Main static output
F = Exchange relay output for main control (5A)
G = Exchange relay output for main control (10A)

C - Alarms

Blank = No alarms
03 = 1 alarm (only with option A or C)

D - Analogue outputs / Set Point

Blank = No analogue outputs/set point
OAP = Analogue outputs (0÷20mA, 4÷20mA, 0÷10V)
RSP = Remote setpoint