



A - Serial outputs

- Z** = No serial outputs
- 2** = RS 422 bi-directional
- 3** = RS 485 bi-directional
- 4** = RS 232 bi-directional
- 12** = RS 422 optoisolated bi-directional
- 13** = RS 485 optoisolated bi-directional
- 14** = RS 232 optoisolated bi-directional

B - Power supply

- 220** = 90÷260 Vac/Vdc
- 24** = 20÷30 Vac/Vdc

C - Output

- A** = Main relay output
- C** = Main static output
- F** = Exchange relay output for main control (5A)

D - Alarms

- Blank** = No alarms
- 03** = 1 alarm (only with option A or C)

E - Analogue outputs / Set Point

- Blank** = No analogue outputs/set point
- OAP*** = Analogue outputs (0÷20mA, 4÷20mA, 0÷10V)
- RSP*** = Remote setpoint

*Available only if there aren't serial outputs